



DELHI TEST HOUSE[®]

(A Unit of Delhi Test House Global LLP)

A-02/3, G.T. Karnal Road, Industrial Area, Near Metro Pillar No. 600, Azadpur, Delhi-110 033 (INDIA)
Ph. : +91-11-47075555 (30 Lines) E-mail : info@delhitesthouse.com
Website : www.delhitesthouse.com

TEST REPORT



Report No.: WT251029001
Report Date: 03-Nov-2025
ULR No.: TC1446125000041216F

Report Issued To : The Principal
Summer Fields School
Kailash Colony, New Delhi, India, 110048

Sample Description:

Sample Name : Drinking Water
Test Reference : IS 10500
Sample Quantity : 2 Ltr + 250 ml
Customer Letter Ref. No. : SFS/2025-26/10
Letter Dated : 28.10.2025

Test Results:

Sr.No	Specific Test	Units	Acceptable Limits	Result	Permissible Limits	Test Method	
Discipline : CHEMICAL Main Group : Water							
Table-1. Organoleptic and Physical Parameter (Clause 4)							
1	Colour	Hazen Unit	Max 5	<1	Max. 15	IS 3025 (P-4)	
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-5)	
3	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-7 & 8)	
4	Turbidity	NTU	Max. 1	<1	Max. 5	IS 3025 (P-10)	
5	pH Value	-	6.5 to 8.5	6.97	No Relaxation	IS 3025 (P-11)	
6	Total Dissolved Solids	mg/l	Max 500	170	Max. 2000	IS 3025 (P-16)	
Table-2. General Parameters Concerning Substances undesirable in excessive amounts (Clause 4)							
1	Total Hardness (as CaCO ₃)	mg/l	Max 200	59.4	Max. 600	IS 3025 (P-21)	
2	Chloride (as Cl)	mg/l	Max. 250	43.2	Max. 1000	IS 3025 (P-32)	
3	Fluoride (as F)	mg/l	Max. 1.0	<0.2	Max. 1.5	APHA 4500F 24th Edition	
Sr.No	Specific Test	Units	LOQ	Acceptable Limits	Result	Permissible Limits	Test Method
Discipline : BIOLOGICAL Main Group : WATER							
Bacteriological test as per Table 6 Clause 4.1.1							
1	Total coliform bacteria	per 100 ml	-	Shall be not detected	Not Detected	-	IS 15185
2	E. coli	per 100 ml	-	Shall be not detected	Not Detected	-	IS 15185
Discipline : CHEMICAL Main Group : Residues in Water							
Table-2. General Parameters Concerning Substances undesirable in excessive amounts (Clause 4)							
1	Iron (as Fe)	mg/l	0.001	Max. 1	BLQ	No Relaxation	IS 3025 (P-65)

BLQ - Below Limit of Quantification | LOQ - Limit of Quantification

Remarks : The sample conforms to IS 10500 :2012 with respect to the above tested parameters only.

Date of Sample Receipt : 29-Oct-2025
Date of Analysis Start : 29-Oct-2025
Date of Analysis Completed : 31-Oct-2025

Reviewed By

AJAY KUMAR SINGH

SR. ANALYST
QR-0302

Page 1 Of 2

Authorised By

M.C. GOEL
Authorised Signatory - Director

SUMAN KUMAR JHA
QUALITY MANAGER

BRANCH OFFICES ALL ACROSS INDIA

DELHI TEST HOUSE®

(A Unit of Delhii Test House Global LLP)

A-62/3, G.T. Karnal Road, Industrial Area, Near Metro Pillar No. 600, Azadpur, Delhi-110 033 (INDIA)
Ph. : +91-11-47075555 (30Lines) E-mail : info@delhitesthouse.com
Website : www.delhitesthouse.com

ESTD. 1976

TEST REPORT

Report No.: WT251029001
Report Date: 03-Nov-2025
ULR No.: TC1446125000041216F



- Note : 1. No Deviation from the Standard Test Method/ Specification is done unless specified or requested by the client.
2. While giving the conformity statement laboratory does not consider Uncertainty Measurement into account
3. General terms & Conditions are given on the back side of the report. Also visit our website WWW.DELHITESTHOUSE.COM for detailed and updated terms & conditions.
4. For report verification email to report_verify@delhitesthouse.com



Scope

***** End Of Report *****

Reviewed By


AJAY KUMAR SINGH

SR. ANALYST

QR-0302

Page 2 Of 2

Authorised By


M.C. GOEL
Authorised Signatory, Director

SUMAN KUMAR JHA

QUALITY MANAGER

BRANCH OFFICES ALL ACROSS INDIA



MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DEPUTY HEALTH OFFICER
PUBLIC HEALTH DEPARTMENT
GREEN PARK, AURBINDO MARG,
NEW DELHI-110016



NO. DHO/SZ/MCD/2025/D- 1362

Dated: 08/11/25

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Sh. Kuldeep Rana, Public Health Inspector from Public Health Department, South Zone inspected Summer Field School located at Kailash Colony, New Delhi - 110048.

It was found that the School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus.

The above certificate is valid for one year from date of issue.

If Building Department or any other Government Agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/ revoked without any further intimation in this regard.

[Handwritten Signature]
08/11/25

Deputy Health Officer
South Zone
Dy. Health Off.
South Zone MCD

Copy to: -

- The Principal
Summer Field School,
Kailash Colony,
New Delhi - 110048